

COMMON-USE ITEMS and EQUIPMENT

PS STANDARD No. OE 024:2014


UNSPSC Code: 46191601-FE-H01

TECHNICAL SPECIFICATIONS

FIRE EXTINGUISHER, PURE HCFC



Pure HCFC 123 (Dichlorotrifluoroethane)
For ABC class of fire
Stored pressure type
Capacity in terms of mass of extinguishing medium: 4.5kg (10lbs)
Purity of the chemical: 99% (min.)
Duration of discharge: 10 seconds (min.)
With pressure gauge control
Non-electrical conductor, non-toxic, non-corrosive
Labeling/Marking: Shall follow PNS 15-5:1996
With PS or ICC Mark
Warranty: Five (5) years standard
Packaging: One (1) unit per box
Reference: PNS 15-5:1996/Amendment 01-1997

TECHNICAL SPECIFICATIONS REVIEW COMMITTEE:


ENGR. MANUEL S. AVILA
Head, Technical Working Group


SIXTO W. ANTONIO, JR.
Senior BAC Chairman


ATTY. JOSE TOMAS C. SYQUIA
Executive Director IV


ENGR. JULIETA M. LOZANO
Chief, Inspection Division

FLERIDA G. ARIAS
Operations Manager

MARCH 2015