

COMMON-USE SUPPLIES and EQUIPMENT

PS STANDARD No. OE 017:2014


UNSPSC Code: 46191601-FE-M01

TECHNICAL SPECIFICATIONS

FIRE EXTINGUISHER, Dry Chemical

Dry Chemical (Mono-Ammonium Phosphate)
For ABC class of fire
Stored pressure type
Capacity in terms of mass of extinguishing medium: 4.5kg (10lbs)
Purity of the chemical: 75% (min.)
Duration of discharge: 10 seconds (min.)
With pressure gauge control
Non-electrical conductor, non-toxic, non-corrosive
Labeling/markings: Shall follow PNS 15 Part 1 of 1989
With PS Mark / ICC Mark
Warranty: Three (3) years standard
Packaging: One (1) unit per box
<i>Reference: PNS 15 Part 1:1989</i>

TECHNICAL SPECIFICATIONS REVIEW COMMITTEE:


ENGR. MANUEL S. AVILA
Head, Technical Working Group


SIXTO V. ANTONIO, JR.
Senior BAC Chairman


ATTY. JOSE TOMAS C. SYQUIA
Executive Director IV


ENGR. JULIETA M. LOZANO
Chief, Inspection Division


FLERIDA G. ARIAS
Operations Manager

JUNE 2015