



Supplemental/ Bid Bulletin No. 2
19 September 2019

PUBLIC BIDDING No. 19-281- 1

Supply, Delivery, Installation, Training and Commissioning of Generator Set and Automatic Transfer Switch (ATS) for the Technical Education and Skills Development Authority (TESDA)

Issued pursuant to Sec. 22.5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by prospective bidders during the Pre-Bid Conference held on **September 17, 2019**.

A. AMENDMENTS

REFERENCE	BASES FOR AMENDMENT
<i>BID DATA SHEET</i>	
ITB Clause 29.2 Page 43 XXX For purposes of Post-qualification the following document(s) shall be required: 3. List of at least two (2) one (1) Service Center in Metro Manila. XXX	<i>To amend the required service center in metro manila.</i>
<i>TECHNICAL SPECIFICATION</i>	
Page 72 XXX <u>GENERATOR SET</u> 1.0 ALTERNATOR DATA <ul style="list-style-type: none">Phase: 1-Phase (2 Wires) or 3-Phase (4 Wires) XXX	<i>To reflect the required number of phase that will fit to the existing connection.</i>
<i>OTHERS</i>	
Attached as Annex A is the corrected parts of the bidding documents.	

All other portions of the Bidding Documents affected by these amendments shall be made to conform to the same.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

The changes made in the Philippine Bidding Documents (5th Edition, August 2016) are deemed integrated in the terms and conditions for this project.

SGD.

ENGR. ROSANA D. YAMBAO
Chairperson, PS-DBM BAC I

29.2	<p>No licenses and permits required.</p> <p>For purposes of Post-qualification the following document(s) shall be required:</p> <ol style="list-style-type: none"> 1. Proof of completion of the single largest contract as identified in the Statement of Single Largest Contract, which shall be copy of any verifiable document(s) such as but not limited to the following: (a) Contract/s or Purchase Order/s; (b) corresponding Sales Invoice/s; (c) Official Receipt/Cash Receipt/Collection Receipt; and (d) Certificate of Satisfactory Completion. 2. Submission of pieces of evidence¹ as proof of compliance with the bidder's actual offer, if applicable. 3. List of at least one (1) Service Center in Metro Manila. 4. Income Tax Returns for year 2018 (BIR Form 1701 or 1702). <p>The income tax and business tax returns stated above should have been filed through the Electronic Filing and Payment System (EFPS).</p> <ol style="list-style-type: none"> 5. Latest Value Added Tax Returns (Forms 2550M and 2550Q) or Percentage Tax Returns (Form 2551M) for the last six months prior to the date of bid opening. 6. Valid and updated PhilGEPS Registration Certificate. 7. Certification accompanied with <i>verifiable</i> proof that the brand being offered has been in the Philippine Market for at least TEN (10) YEARS. <p><i>N.B. Documents submitted during post-qualification as part of post-qualification documents must be certified by the authorized representative to be true copy/ies from the original.</i></p>
32.4(f)	No additional requirement.

¹ In the column "Bidder's Compliance", the bidder must state "comply" against each of the individual parameters of each specification corresponding to performance parameter of equipment offered. Statement of "comply" must be supported by evidence in a bidders bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's or distributor's un-amended sales literature, unconditional statements or specification and compliance issued by the manufacturer or distributor, samples, independent test data etc., as appropriate.

TECHNICAL SPECIFICATIONS

ITEM : GENERATOR SET WITH AUTOMATIC
 QUANTITY : 1 unit
 APPROVED BUDGET FOR : 701,155.00
 THE CONTRACT

TECHNICAL SPECIFICATIONS	QUANTITY	SUPPLIER'S OFFER/ BIDDER'S STATEMENT OF COMPLIANCE
<u>GENERATOR SET</u> 1.0 ALTERNATOR DATA <ul style="list-style-type: none"> • Output : 40 KVA • Standby Output : 32 KVA • Frequency and Speed: 50Hz/60Hz • Output Rating (Continuous) : 30 / 35 • Output Rating (Standby) : 32 / 37.5 • Voltage (V): 220-240 / 380- 440 • Phase: 1-Phase (2 Wires) • Voltage Regulator: $\pm 1.5\%$ • Rated Power Factor: 0.8(Lagging) • Excitation System: Brushless, Rotating Exciter (with A.V.R.) • Insulation Class: H 2.0 ENGINE DATA <ul style="list-style-type: none"> • Engine Type: Diesel • Number of Cylinders: Four (4) • Output Rating (Kw/rpm) : 33/1500 / 35/1800 • Piston Displacement (L): 2.771 • Fuel Consumption <ul style="list-style-type: none"> ○ 75% Standby Power (L/Hr): 3.8 / 4.5 (max.) • Lube Oil Capacity (L) : 6 	1 UNIT	BRAND AND MODEL: