



BID BULLETIN NO. 2
13 APRIL 2023

PUBLIC BIDDING NO. 007-2023

**Supply, Delivery, Installation and Commissioning of Air Conditioning Units
for the Procurement Service- Department of Budget and Management
(PS-DBM)**

Issued pursuant to Sec. 22.5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project.

I. CLARIFICATIONS

CLARIFICATION/S	RESOLUTION/S
GENERAL	
Page 31 Section VII. Technical Specification XXX Voltage, Frequency, Phase: 209-240V/60Hz/1Ph XXX <ul style="list-style-type: none">Bidder's representative clarified the Power Requirement if a 230V ACU will be allowed. XXX installation of copper tubes, drain pipes, and drain pumps (if applicable); XXX <ul style="list-style-type: none">Bidder's representative clarified if all ACU will be installed with additional pump considering that ceiling cassette ACU's have already built-in pumps.	<p>As long as the offered product's voltage is within the 209-240V requirement, the offer is acceptable.</p> <p>To clarify, the installed air conditioning system shall be capable of disposing of the condensate water produced by the air conditioning units. The necessity of installing additional pumps depends on the manner by which the air conditioning system is installed. Thus, bidders are advised to consider all possible costs in preparing their financial proposal. To help prospective bidders in cost estimation, they are encouraged to conduct site visit, details of which are provided below.</p>

<p>xxx</p> <p>NEMA 3R Enclosure with circuit breaker</p> <p>xxx</p> <ul style="list-style-type: none"> Bidder's representative clarified if a Miniature Circuit breaker will be allowed. 	<p>As long as the offered product is within the minimum requirement of NEMA 3R, the offer is acceptable.</p>
<p>xxx</p> <p>Dismantling of old/existing units; and</p> <p>xxx</p> <ul style="list-style-type: none"> Bidder's representative clarified if all old/existing units have dismantling works. 	<p>Only five (5) units are required for dismantling.</p>

The Internal Bids and Awards Committee will allow the conduct of site visit for the project on 14 April 2023; 10:00 A.M. The Procuring Entity's Representative on-site is Engr. Neil Christian C. Dag-uman, OIC-Chief, GSD.

All other portions of the Bidding Documents affected by these amendments shall be made to conform to the same.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

The changes made in the Philippine Bidding Documents (6th Edition, July 2020) are deemed integrated in the terms and conditions for this project.

Signature Redacted

ENGR. JAIME M. NAVARRETE JR.
Chairperson, Internal Bids and Awards Committee

For the purpose of this Bulletin and for better understanding of its contents, the following rules shall apply: (a) Double Strike out – denotes deletion; (b) Underline – denotes inclusion or new item/requirement; and "xxx" – denotes separation of phrase/s being amended from the rest of the main text.